

H. Off. : M-577, Guru Harkishan Nagar, Paschim Vihar, New Delhi-110087 (India)  
 Laboratory : 198-199, MIE, Phase-1, Bahadurgarh, Haryana - 124507 (India)  
 E-mail : info@alphatesthouse.com, support@alphatesthouse.com

+91-11-79653542, 8527763108  
 +91 1276-661500, 8130453334  
 www.alphatesthouse.com

TEST REPORT

Test Report No.:	ATL1770042023	ULR No.:	TC644623000002013F	Letter Date :	23/06/2023
Name and Address of Customer :	INDIAN MODERN SCHOOL, C Block, Chattarpur Enclave, New Delhi - 110074.				
Sample Received Date :	26/06/2023	Start Date of Analysis :	26/06/2023		
Report Issue Date :	28/06/2023	End Date of Analysis :	27/06/2023		
Sample Name :	Drinking Water				
Description of the Sample :	Water for Drinking Purpose				
Sample Drawn By :	By Customer	Grade/Variety/Size/etc. :	N/A		
Name of Work :	N/A	Environmental Condition :	N/A		
Location of Sampling point :	N/A	Brand Name, if any :	N/A		
Batch No./Lot No. :	N/A	Date of Expiry :	N/A		
Date of Mfg. :	N/A	Component Value :	N/A		
Sample Quantity Received :	1 Ltr.				
Reference No :	Ims/k.w.t/01/23-24/(126)				
Declared Value if any :	N/A	Indian Standard Reference :	IS:10500-2012		
Agreement No. :	N/A	Mode of Packing :	N/A		
Name of Agency :	N/A				
Any Other Information (if any) :	--				
Test Report Form No. :	ATHB/7.8/F01				
Test Report Form(s) Originator :	Alpha Test House, Bahadurgarh				
Issue No. & Issue Date :	02 & 31/12/2022				
Amendment No. & Date :	00_				

TEST REPORT

Sr. No.	Test Parameters	Units of Measurements	Results	Requirement as per IS:10500-2012 (Reaffirmed-2018)		Method Reference
				Acceptable limit	Permissible limit	
<b>CHEMICAL PROPERTIES</b>						
1.	Colour	Hazen units	BDL (DL-1)	5 Max.	15 Max.	IS:3025(P-4)-2021
2.	Odour	--	Agreeable	Agreeable	Agreeable	IS:3025(P-5)-2018
3.	Turbidity	NTU	BDL (DL-0.1)	1 Max.	5 Max.	IS:3025(P-10)1984 RA-2022
4.	pH value	--	6.98	6.5-8.5	No relaxation	IS:3025(P-11)-2022
5.	Total Hardness as CaCO <sub>3</sub>	mg/l	60	200 Max.	600 Max.	IS:3025(P-21)2009 RA-2019
6.	Iron as Fe	mg/l	BDL (DL-0.05)	1.0 Max.	No relaxation	IS:3025(P-53)2003 RA-2019
7.	Chloride as Cl	mg/l	50	250 Max.	1000 Max.	IS:3025(P-32)1988 RA-2019
8.	Total Dissolved Solid	mg/l	134	500 Max.	2000 Max.	IS:3025(P-16)-2023

