

H. Off. : M-577, Guru Harkishan Nagar, Paschim Vihar, New Delhi-110087 (India)  
 Laboratory : 198-199, MIE, Phase-1, Bahadurgarh, Haryana - 124507 (India)  
 E-mail : info@alphatesthouse.com, support@alphatesthouse.com


+91-11-79653542, 8527763108  
 +91 1276-661500, 8130453334  
 www.alphatesthouse.com

TEST REPORT

Test Report No.:	ATL1770042023	ULR No.:	TC644623000002013F	Letter Date :	23/06/2023
Name and Address of Customer :	INDIAN MODERN SCHOOL, C Block, Chattarpur Enclave, New Delhi - 110074.				
Sample Received Date :	26/06/2023	Start Date of Analysis :	26/06/2023		
Report Issue Date :	28/06/2023	End Date of Analysis :	27/06/2023		
Sample Name :	Drinking Water				
Description of the Sample :	Water for Drinking Purpose				
Sample Drawn By :	By Customer	Grade/Variety/Size/etc. :	N/A		
Name of Work :	N/A	Environmental Condition :	N/A		
Location of Sampling point :	N/A	Brand Name, if any :	N/A		
Batch No./Lot No. :	N/A	Date of Expiry :	N/A		
Date of Mfg. :	N/A	Component Value :	N/A		
Sample Quantity Received :	1 Ltr.				
Reference No :	Ims/k.w.t/01/23-24/(126)				
Declared Value if any :	N/A	Indian Standard Reference :	IS:10500-2012		
Agreement No. :	N/A	Mode of Packing :	N/A		
Name of Agency :	N/A				
Any Other Information (if any) :	--				
Test Report Form No. :	ATHB/7.8/F01				
Test Report Form(s) Originator :	Alpha Test House, Bahadurgarh				
Issue No. & Issue Date :	02 & 31/12/2022				
Amendment No. & Date :	00_				

TEST REPORT

Sr. No.	Test Parameters	Units of Measurements	Results	Requirement as per IS:10500-2012 (Reaffirmed-2018)		Method Reference
				Acceptable limit	Permissible limit	
<b>CHEMICAL PROPERTIES</b>						
1.	Colour	Hazen units	BDL (DL-1)	5 Max.	15 Max.	IS:3025(P-4)-2021
2.	Odour	--	Agreeable	Agreeable	Agreeable	IS:3025(P-5)-2018
3.	Turbidity	NTU	BDL (DL-0.1)	1 Max.	5 Max.	IS:3025(P-10)1984 RA-2022
4.	pH value	--	6.98	6.5-8.5	No relaxation	IS:3025(P-11)-2022
5.	Total Hardness as CaCO <sub>3</sub>	mg/l	60	200 Max.	600 Max.	IS:3025(P-21)2009 RA-2019
6.	Iron as Fe	mg/l	BDL (DL-0.05)	1.0 Max.	No relaxation	IS:3025(P-53)2003 RA-2019
7.	Chloride as Cl	mg/l	50	250 Max.	1000 Max.	IS:3025(P-32)1988 RA-2019
8.	Total Dissolved Solid	mg/l	134	500 Max.	2000 Max.	IS:3025(P-16)-2023





①

**MUNICIPAL CORPORATION OF DELHI**  
**PUBLIC HEALTH DEPARTMENT : SOUTH ZONE**  
**GREEN PARK, AUROBINDO MARG NEW DELHI 110016**

No: DHO/SZ/MCD/2023/D- 934

Dated .....12/7/23

**SCHOOL HEALTH CERTIFICATE**

1. Name of the School	Indian Modern School		
2. Address	Chattarpur Enclave, New Delhi-110074		
3. No. of Shift	Morning	Timing	8AM to 2PM
4. No. of Students: Boys	107	Girls	74
			Total 181
5. No. of Staffs: Male	7	Female	20
			Total 27

**Details of Accommodations present in School**

1. Floor Space in the Classroom Sufficient/insufficient : Sufficient
2. The Classrooms are Well Lighted/ ill lighted : Well Lighted
3. The Classrooms are Well Ventilated/ ill ventilated : Well Ventilated
4. The Classrooms are kept / Not kept Neat & Clean: kept Neat & Clean
5. The Classrooms/Building requires/ do not required Whitewash etc. Whitewash
6. The Drinking Water is Wholesome/ not wholesome : Drinking Water is Wholesome
7. The Latrine arrangement is Sanitary/ insanitary : Sanitary

**No. of toilets seats for student**

1. One latrine-cum-urinal is required for 25 female students are sufficient.
2. One latrine for 40 male students is required is sufficient.
3. Separate Toilet arrangement for staff. present: Yes/No : Yes
4. The Overall facilities: Good/ Adequate/Inadequate : Good

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remarks: Certificate is valid for One Year)

New Delhi

*Dr. Deepak Mittal*  
Deputy Health Officer

South Zone, MCD  
Dr. Deepak Mittal  
Dy. Health Officer/SZ